

KA-140 Installation Instructions





KA-140 Mounting Instructions

MOOREAutomation inc.


For more information or assistance in mounting your switch please contact us.

Call us toll-free: 877-767-6897 or Phone: 507-639-9031 Fax: 507-639-6488

Email: mooreaut@frontiernet.net Address: 411 Main Street East, P.O. Box G, Trimont, MN 56176

Office Hours: 8-5 p.m. Monday - Friday / Support hours: 24 hours a day, every day on MOOREAutomation products

REVISIONS	
DESCRIPTION	DATE
NEW RELEASE	12/15/13
REV A -UPDATED TEXT	01/13/15
REV B -UPDATED TEXT	02/08/20



VOLTAGE SELECTION

FOR 110V - PUT JUMPERS ON THE OUTTER

PINS MARKED 110V (IF ONLY ONE JUMPER

IS ON THE BOARD REMOVE THE JUMPER

THAT IS GLUED TO THE TOP OF THE

RELAY)

FOR 220V - PUT ONE JUMPER ON THE

CENTER PINS MARKED 220V

L1-LINE #1
L2-NEUTRAL OR LINE #2

-INDICATES WIRENUT CONNECTION
NC-NORMALL CLOSED (ON)
NO-NORMALLY OPEN (OFF)



MODRE AUTOMATION 411 EAST MAIN STREET TRIMONT, MN 56176 (507) 639-9031

MA1C-110V / MA1C-220V RELAY